

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CT0207

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	CHAFFOTEAUX SAS Le Carré Pleyel, 5 rue Pleyel, F-93521 St. Denis - Cedex
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	wall hanging condensing boiler with integrated gas burner in modulating operation method
Model <i>Modell</i>	PIGMA ADVANCE...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, RS, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K2354 2018 B2 from 17.05.2018 (TRG) type testing: K 2354 2018 T1 from 17.05.2018 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 18.06.2028 / 18-0239-GEE
Ablaufdatum / AZ

18.06.2018 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz

Appliance Categories Gerätekategorien	Supply Pressures Versorgungsdrücke	Countries of Destination Bestimmungsländer	Remarks Bemerkungen
I2E	20 mbar	DE, LU	
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK, EE, FI, LV, NL, NO, SE	
I2L	25 mbar	NL	
I3P	28-30 mbar	CY	
I3P	50 mbar	DE	
II2E(S)3P	20/25, 37 mbar	BE	
II2ELwLs3P	20,20,13, 30 mbar	PL	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	LT	
II2H3P	20, 37 mbar	CH, CZ, ES, GB, GR, HR, IE, IS, PT, RO, SI, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
PIGMA ADVANCE IN 25; PIGMA ADVANCE IN SYSTEM 25; PIGMA ADVANCE EXT 25	sanitary water heat input (Hi): 3,7...26,0 kW nominal heat output: 3,4...21,4 kW heat input (Hi): 3,7...22,0 kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

flue types: B23, B23P, B33, C13(x), C23, C33(x), C43(x), C53(x), C63(x), C83(x) and C93(x) according to installation manual with flue systems of Centrotec (approval no. 0036 CPR 9169 003), Muelink & Grol (approval no. 0432-BPR-220556), Skoberne (approval no. 0036 CPD 9184 001-2007), Groppalli (approval no. 0694-CPR-7968), LN Natalini (approval no. 0694-CPR-8045) and SIT (approval no. 0476-CPR-8045)

Additional proved countries of destination, appliance categories and supply pressures:

BG: II2H3P (20, 30 mbar)

CY: I2H (20 mbar)

AL, MK, MT, RS: II2H3P (20, 37 mbar)

In Albania, Macedonia and in Serbia the CE-marking will be accepted as conformity approval if the EU-Gas Appliance Regulation (EU/2016/426) is transferred into national law by Albania, Macedonia and Serbia.

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CT0207

Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EC Efficiency Directive (92/42/EEC)
EG-Wirkungsgradrichtlinie (92/42/EWG)**Distributor**
*Vertreiber*CHAFFOTEAUX SAS
Le Carré Pleyel, 5 rue Pleyel, F-93521 St. Denis - Cedex**Product Category**
Produktart

Boilers with flue systems: Condensing water heater (3202)

Product Description
Produktbezeichnung

wall hanging condensing boiler with integrated gas burner in modulating operation method

Model
Modell

PIGMA ADVANCE...

Type of Boiler
Heizkesseltyp

condensing boiler

Test Reports
Prüfberichte

type testing: K 2354 2018 B3 from 17.05.2018 (TRG)

Test Basis
Prüfgrundlagen

EU/92/42 (21.05.1992)

File Number
Aktenzeichen

18-0239-GWE

70028-04-A-DE

18.06.2018 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
PIGMA ADVANCE IN 25; PIGMA ADVANCE IN SYSTEM 25; PIGMA ADVANCE EXT 25	sanitary water heat input (Hi): 3,7...26,0 kW nominal heat output: 3,4...21,4 kW heat input (Hi): 3,7...22,0 kW	